



CONNECTIONS FOR REMOTE MOUNTED SMOKE DETECTOR
 A17, MAX LOAD 0.1VA 24VAC CLASS II
 FUSE F15 MAY NOT BE USED ON "J" UNITS
 TRANSFORMER USED ON "J" UNITS
 OVERLOAD USED ON 7.5 HP MOTOR & "M" UNITS
 FUSE # & 0 UNITS ONLY

LENNIX Corporation Inc. WIRING DIAGRAM 3/91
 COMBINATION UNITS-ROOFTOP
 GCS11-2753, 3003-7-W, 0,6, J, M
 HEAT, COOL SECTION B20
 575VOLT UNITS 620, 252W 575VOLT UNITS 529, 330W
 LITHO U.S.A.