



IMPLANTATION DU MATERIEL

MODELES	COMP.	PUISS.	Ø A	Ø A'	Ø R	Ø R'	Ø L	Ø D	Ø E	Ø S	EVAPORATEUR	DESURCHAUFFEUR
300	CP 1 CP 2	1x15 1x15	1"3/8 1"3/8	2"1/8	7/8" 7/8"	1"1/8	7/8"	1"3/8	2"1/8	1"5/8	EXEL 14-50	EXEL 8-30
250	CP 1 CP 2	1x15 1x10	1"3/8 1"1/8	1"5/8	7/8" 3/4"	1"1/8	7/8"	1"1/8	2"1/8	1"5/8	EXEL 14-50	EXEL 8-30
200	CP 1 CP 2	1x10 1x10	1"1/8 1"1/8	1"5/8	3/4" 3/4"	7/8"	7/8"	1"1/8	1"3/8	1"5/8	EXEL 14-30	EXEL 8-20
150	CP 1	1x15	1"3/8	1"3/8	7/8"	7/8"	5/8"	1"1/8	1"3/8	7/8"	EXEL 7-60	EXEL 4-20
100	CP 1	1x10	1"1/8	1"1/8	3/4"	3/4"	5/8"	7/8"	1"3/8	7/8"	EXEL 7-40	EXEL 4-20

AD	39	14.II.00	DEPLACER LE VOYANT HYGROSCOPIQUE
MODIFIE PAR	IND	N.ETUDE	DATE
APPAREIL OU UNITE			MATIERE:
LD-LDH 100 A 300			
DESIGNATION		ECHELLE	TRAITEMENT
SCHEMA FRIGORIFIQUE		FOLIO	MASSE:
NUMERO DE COMMANDE:		FORMAT	REMPLECE PAR:
NOTE D'ETUDE:		DATE:	REMPLECE:
VERIFIE PAR:		DATE:	NUMERO DE PLAN
DESSIN PAR:		DATE: 27.03.98	INDICE



A3 3956353 39